


MAINTAIN 18" VERTICAL OR 10'  
HORIZONTAL SEPARATION DISTANCE  
BETWEEN SANITARY SEWER AND  
WATER MAIN



PUBLIC WORKS DIRECTOR