



NOTES:

1. SEE STANDARD DETAILS FOR PRE CAST REINFORCED CONCRETE MANHOLE, CAST IRON MANHOLE FRAME AND COVER, MISCELLANEOUS MANHOLE DETAILS, AND TYPICAL TRENCH SECTION.
2. FIBERGLASS OR PLASTIC STEPS SHALL BE INSTALLED AT 12" VERTICAL FROM 12" (MAX) BELOW T.F. ELEV. TO 12" (MAX.) ABOVE INSIDE BOTTOM ELEV. AT EACH ACCESS POINT.
3. ALL PIPES SHALL BE CUT FLUSH WITH INSIDE WALLS.

NOT TO SCALE

TOWN OF SOUTH WINDSOR
STANDARD DETAIL

MARCH, 2005

**SEDIMENTATION STRUCTURE
TYPE I (SHEET 2 OF 2)**

REVISED:

APPROVED

PUBLIC WORKS DIRECTOR