



SOUTH WINDSOR FIRE MARSHAL

EMERGENCY LIGHTING TEST LOG

The Connecticut Fire Safety Code requires that all battery-powered emergency lights be tested monthly for 30 seconds and annually for 90 minutes. The Code also requires that written records of those tests be kept by the owner for inspection by the local Fire Marshal. Below an emergency lighting test log for your use.

Business Name/Address: _____ Year: _____

Fixture Location / #	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Annual Test



Office Address: 232 West Road, South Windsor, CT 06074
Mailing Address: 1540 Sullivan Ave, South Windsor, CT 06074
(860) 282-0669 www.southwindsor.org