



2022 Connecticut Fire Fire Marshal's Association

TYPE OF ALARM(S): The type of alarms required in a dwelling depends upon the age of the property based on the date of the Building Permit (BP) was issued. Smoke alarms are required on every occupied floor and basements. On May 1,1999 including one on every floor smoke alarms in sleeping areas were added.

BP issued Prior to 10/1/1976	BP Issued From 10/1/1976 and Prior to 10/1/1985	BP Issued as of 10/1/1985	BP Issued as of 10/16/1989	BP issued as of May 1, 1999
Alarm may be battery or A/C hardwired.	A/C hardwired alarm required.	A/C hardwired alarm with battery backup.	All smoke alarms are required to be interconnected to alarm simultaneously.	Detectors are now required in all sleeping areas.

•	Minimum requirements require at least one smoke alarm on each level and in the immediate vicinity of each bedroom.