

**MEMBERS OF THE WPCA THAT ARE UNABLE TO ATTEND THIS MEETING, PLEASE
CALL ETHER DIAZ, (860) 644-2511, EXT. 243, ON OR BEFORE 4:30 P.M. ON THE DAY OF
THE MEETING**

***WATER POLLUTION CONTROL AUTHORITY
TOWN OF SOUTH WINDSOR***

**SPECIAL MEETING
SPRENKEL ROOM**

AGENDA

**JUNE 8, 2015
6:00 P.M.**

A. ROLL CALL

B. NEW BUSINESS

1. Carla's Pasta, 50 Talbot Lane - (Approval)

C. ADJOURNMENT

**WATER POLLUTION CONTROL AUTHORITY
TOWN OF SOUTH WINDSOR**

**REVISED MINUTES
SPRENKEL ROOM**

PAGE 1

**SPECIAL MEETING
JUNE 8, 2015**

A. ROLL CALL

Members Present: Richard Aries, Donald Antaya, Robert Dickinson, Ed Havens, Jr., and William Vees

Members Absent: Carol Fletterick and Vicki Paliulis

Alternates Present: Richard Siedman sitting in for Carol Fletterick

Alternates Absent: M. Atif Quraishi

Staff Present: C. Fred Shaw, Superintendent of Pollution Control
Ether A. Diaz, WPCA Recording Secretary

Others Present: Andy Krar, Design Professionals, Inc.

Chairman Richard Aries called the meeting to order at 6:00 p.m. The following actions were taken during the June 8, 2015 Special Meeting of the Water Pollution Control Authority (WPCA).

B. NEW BUSINESS

1. Carla's Pasta, 50 Talbot Lane - (Approval)

Andy Krar of Design Professionals was in attendance and presented the application. He explained that this application is for the expansion of Carla's Pasta located at 50 Talbot Lane, South Windsor, CT. This is going to be an 180,000 square foot expansion of the existing facility. The project has received approval from P&Z and the Inland Wetlands Commission. The existing connection of the sanitary sewer goes into Talbot Lane; the expansion will be hooked up to existing sanitary sewer on Nutmeg Road South.

There will be a new manhole in the right of way which will be right on top of the existing sewer line on Nutmeg Road South. There is a 206' and 240' length of pipe between the proposed sewer pipe. Mr. Krar was advised to put cleanouts at everyone 100 feet in between the proposed manholes.

Chairman Aries expressed that Carla's Pasta is one of the properties that uses a large amount of water; perhaps they may want to consider installing a private meter for the purposes of measuring water that does not go in the system. Mr. Shaw explained that they have a discharge meter on the process line which discharges to the sewer. There is a formula that is used to determine the total amount of water that actually discharges into the sewer from the existing two lines.

Mr. Shaw explained that a 1000 gallon grease interceptor has been proposed. In the plans they show a line that bypasses the interceptor and a line that goes in the interceptor, so there is a large flow that will go through to Nutmeg Road South. Therefore, Mr. Shaw asked for the computations used to justify the size of the interceptor.

**WATER POLLUTION CONTROL AUTHORITY
TOWN OF SOUTH WINDSOR**

**REVISED MINUTES
SPRENKEL ROOM**

PAGE 2

**SPECIAL MEETING
JUNE 8, 2015**

Motion was made for approval of the proposed connection to the Town's sewerage system for the addition of the 180,000 square foot commercial building located at 50 Talbot Lane, South Windsor, CT; as more specifically shown on plans entitled "Carla's Pasta, 50 Talbot Lane & 280 Nutmeg Road South, South Windsor, Connecticut, Site Plan Modification"; Prepared by Design Professionals, Inc., South Windsor, CT; Project No. 1293.D, Dated 3/31/15, Sheet No. UT-2 "Utility Plan", Revisions Date: 5/18/2015. This approval is subject to the following conditions: (1) Installation of a cleanout at every 100 feet between the proposed manholes; (2) submittal of the computations used to justify the size of the 1000 gallon grease interceptor.

The motion was made by Mr. Dickinson and seconded by Mr. Donald Antaya;
The motion carried unanimously

C. ADJOURNMENT

Motion was made to adjourn the meeting at 6:15 a.m.

The motion was made by Mr. Ed Havens, Jr. and seconded by Mr. Richard Siedman. The motion carried unanimously

Respectfully Submitted,

Ether A. Diaz, Recording Secretary